

SOAH DOCKET NO. 473-21-0538
PUC DOCKET NO. 51415

RECEIVED
2021 MAY 20 AM 11:04
PUBLIC UTILITY COMMISSION
FILING CLERK

SOUTHWESTERN ELECTRIC POWER COMPANY'S RESPONSE
TO CITIES ADVOCATING REASONABLE DEREGULATION'S
FIRST SET OF REQUESTS FOR INFORMATION

Question No. CARD 1-23:

Provide SWEPCO's total system annual SAIDI and SAIFI with and without major storms for each of the last four years and for the test year in this case.

Response No. CARD 1-23:

Please see CARD 1-23 Attachment 1 for SWEPCO's total company annual SAIDI and SAIFI with and without major storms.

Prepared By: Paul D. Flory

Title: Regulatory Consultant Sr

Sponsored By: Drew W. Seidel

Title: VP Dist Region Ops

Data Includes Major Storms

Year	OpUnit	SAIDI	SAIFI
2016	SWEPCO	307.80	1.90
2017	SWEPCO	573.52	2.12
2018	SWEPCO	334.26	1.89
2019	SWEPCO	644.08	2.29
Test Year	SWEPCO	668.39	2.31

Data Does Not Include Major Storms

Year	Operating Unit ID	SAIDI	SAIFI
2016	SWEPCO	179.26	1.62
2017	SWEPCO	205.87	1.65
2018	SWEPCO	257.70	1.78
2019	SWEPCO	238.17	1.67
Test Year	SWEPCO	263.39	1.69